# FC34B02-M12

## Material

PPA - Polyphthalamide















**How it works** A fluid flow through the sensor causes precise displacement of a magnetic piston and closes an electrical contact (reed switch).

- **Details** On/Off output; NO (SPST) working;
  - Detects increased or decreased flow;
  - Sensitivity adjustment<sup>1</sup>.



Actuation Range (in LPM)				
Water				
From ~2.1 to ~52				

- **Typical applications** Lubrification and cooling systems monitoring;
  - · Pipe fluid flow monitoring.

**Liquids** • Clean water, oils, lubricants and filtered fuels<sup>2</sup>.











Liquids with magnetic particles will cause deposition/magnetic sedimentation and it will prejudice the operation of the sensor. Use magnetic filter before the sensor.

Liquids with encrustation particles and/or solids require tests.

### **Technical specifications**

Internal clearance Maximum operation pressure Operating temperature range


Inlet/outlet port Spring Sealing Output connection

> **Enclosure rating** Electrical contact


266mm<sup>2</sup> 25bar 0°C to 100°C | 140°C @1h G 3/4" female (BSP - Parallel) AISI 302 stainless steel NBR (nitrilic rubber) O'Ring M12 male plug (2 pins) M12 female connector NOT included Reed Switch 20W/VA


The sensors work in all voltage and current ranges displayed in the table bellow:				
Operating Voltage	Max. Switching Power	Max. Switching Current	<b>Peak Current</b>	
110Vac	20VA	0.2A	0.5A @20ms	
220Vac	20VA	0.1A	0.5A @20ms	
5Vdc	2.5W	0.5A	1A @20ms	
12Vdc	5W	0.5A	1A @20ms	
24Vdc	10W	0.5A	1A @20ms	
<b>24Vac:</b> Recommended use with Schneider coupling relay model RSLZVA1.				

# • Typical connection to contactor



Installing the snubber filter extends the lifespan of the sensor's electrical contact.





### **Notes**

<sup>&</sup>lt;sup>1</sup> In water. Set point accuracy: ±15%.

Repeatability (not considering the viscosity change of liquids): ±10%.

<sup>&</sup>lt;sup>2</sup> For application in oil, recommended model FC34B04-M12.